

Stormwater Management

410-887-3768

March 29, 2019

Johnson, Mirmiran and Thompson
40 Wight Avenue
Hunt Valley, MD 21030
Attn: Stephen Crowe, P.E.

RE: Columbia Gas Transmission, LLC
SIAP 367 Line MA Pipe Replacement
Vicinity Rosewood Lane, Owings Mills
Stormwater Management Variance
Gwynns Falls Watershed
EPS Project I.D. A118244
EPS Tracking Number: 02-19-2962

Dear Mr. Crowe:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the replacement of approximately 100 feet of pipeline by cut and cover. The existing cover conditions will be re-established once the project is completed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Michael P. Doyle of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

David V. Lykens, Acting Director
Department of Environmental Protection
& Sustainability

DVL:jcm

c: Michael P. Doyle